

Clear the Air

BAAQMD Reg. 9 Rule 7

Nitrogen Oxides and Carbon Monoxide from Industrial, Institutional and Commercial Boilers, Steam Generators and Process Heaters

Emission Limit	Rated Heat Input (million BTU/hr)	NOx Limit (ppmv)	CO Limit (ppmv)
307.1	>2 to 5	30	400
307.2	>5 to <10	15	400
307.3	10 to <20	15	400
307.4	20 or more, load-following unit	15	400
307.5	20 to <75	9	400
307.6	75 or more	5	400
307.7	10 or more, landfill gas-fired or digester gas-fired device	30	400
307.8	1 or more while firing only non-gaseous fuel	40	400
307.9	1 or more while firing a combination of gaseous and non-gaseous fuel	Heat-input weighted average of gaseous and non-gaseous limit	400
307.10	10 or more, while operated under exemption 9-7-112.2	30	400

Clear the Air

COMPLIANCE SCHEDULE

(Adopted July 30, 2008)

Section	At least 33% of devices at a single facility	At least 66% of devices at a single facility	100% of devices at a single facility
9-7-307.1	Effective Date: After Jan. 1, 2011 OR 10 years after original manufacture date if manufactured prior to Jan. 1, 2011	One year after Effective Date	Two years after Effective Date
9-7-307.2 9-7-307.3	Effective Date: After Jan. 1, 2012 OR 10 years after original manufacture date if manufactured prior to Jan. 1, 2012	One year after Effective Date	Two years after Effective Date
9-7-307.4 9-7-307.5 9-7-307.6	Effective Date: After Jan. 1, 2012 OR 5 years after original manufacture date if manufactured prior to Jan. 1, 2012	One year after Effective Date	Two years after Effective Date
9-7-307.7 9-7-307.10	July 30, 2008	July 30, 2008	July 30, 2008
9-7-307.8 9-7-307.9	Effective Date: Jan. 1, 2011 for devices with rated input <10 MM Btu/hr OR July 30, 2008 for devices with rated input 10 MM Btu/hr	One year after Effective Date	Two years after Effective Date

Last Amended 5/4/2011

www.baaqmd.gov